

Rain and Hail, LLC  
Urbandale, Iowa  
Permit Number 02615

## II. SPECIFIC CONDITIONS - PLANT

Permit conditions are established in accord with Polk County, Board of Health Rules & Regulations Chapter V, Article X.

---

### A. Permit Duration

The term of this permit is one calendar year commencing on the first day of 2010.

### B. Facility Emissions Limitations and Conditions

#### 1. Emissions limits

The permittee shall not allow atmospheric emissions from the plant to exceed the following:

<u>Pollutant</u>	<u>lbs/hr.</u>	<u>tons/year</u>	<u>Allowable Concentration</u>	<u>Applicable Requirement</u>
				Chapter V, Article IX Section 5-27
PM <sub>10</sub>	0.43	0.11	---	
Opacity		---	---	<20%
SO <sub>x</sub>	1.55	0.39	---	
NO <sub>x</sub>	9.83	2.46	---	
VOC	0.28	0.07	---	
CO	2.61	0.65	---	

#### 2. Operating limits, standards and other emissions-related requirements

The permittee shall not allow the operation of this source to exceed the following:

---

#### Operating Conditions

---

1. Each generator shall have installed a non-resettable totalizing hour meter. Monthly readings shall be taken and logged on site. Said log shall be made available to representatives of this department upon request.
  2. Operation shall be limited to 500 hours per 12 month period rolled and totaled monthly.
  3. Only distillate fuel meeting ASTM standards for sulfur content shall be used. A copy of fuel supplier certification of sulfur content shall be maintained on site and made available to representatives of this department upon request.
  4. A Current hour meter reading shall be submitted with the annual operating permit application.
-